

**GOVERNMENT OF TELANGANA**  
**STATE DISASTER RESPONSE AND FIRE SERVICES DEPARTMENT**



To, NAWAB SHAH ALAM  
M/s. KHAN COLLEGE OF  
ENGINEERING AND TECHNOLOGY  
16-4-1, New malakpet,  
HYDERABAD. (T.S.) Hyderabad.

Office of the  
Station Fire Officer,  
Fire Station, Turn Table Ladder,  
Hyderabad. T.S.

Sir,

**Sub :** Telangana State Disaster Response & Fire Service Department - Centre Region -  
Hyderabad District - Fire Station Turn Table Ladder - Fire Protection and Control  
Inspection of M/s. NAWAB SHAH ALAM KHAN College of E&T malakpet  
of premises against Fire Precautionary and Preventive Measures.

- Ref. :**
1. Annexure - XVII of fire Services Manual Rules.
  2. D.O. Lr. No. 4646/ Genl.B/A1/2002, dated : 10-08-2002, of the Principal Secretary to Govt., Home Department, T.S. Secretariat, Hyderabad.
  3. D.O. Lr.No. 856/B2/99, Dt. 04-09-2002, of the Director General of Fire Services.
  4. Application Dated \_\_\_\_\_ of name \_\_\_\_\_

\* \* \* \* \*

On inspection of the above mentioned premises on 04/04/2023 it was found that the Fire Precautionary Measures have been taken / have not taken in the below maintain premises.

1. Four No's. of ABC Fire Extinguishers of 6 Kg. should be provided.
2. Two No's. of water CO2 of 9 ltrs, capacity should be provided.
3. Two No's. of Dry Chemical powder each 5Kgs. Capacity should be provided.
4. Two No's. of CO2 Fire Extinguishers of 4.5 Kgs. Capacity should be provided.
5. Four No's. of Fire Buckets round bottomed each 19 Ltrs. Capacity are provided with water/dry sand and hanged on to a stand at an accessible point in the premises.
6. 10,000 Litres of Terrace Water tank should be provided.
7. 15,000 Litres of Static Water Tankl should be provided.
8. One of the First Aid Box with its complete Medicines should be provided.
9. Electrical wiring should be checked periodically and ensure no Loose Wiring.
10. All the Employees should be observed throughout the premises.
11. General Cleaniness should be observed throughout the premises.
12. One pair of Rubber Hand Gloves Should be provided near the Electrical Main.
13. Emergency lighting with 2 Hours battery provided.

**Note :**

The management is requested to provide the Fire Fighting Installation as per the national building Code of India 2005, Part IV Table 23 and as per G.O. Ms. No. 154, MA & UD Department, Dt. 13-03-2007, Memo No. 4011/M1/2008 of MA & UD (M1) Dt. 19-05-2008.

The Management is requested to provide the Fire Fighting equipment in good working condition to tackle the Fire in case of Emergency.

Next date of Inspection is April 2024

All Equipments are in good condition  
only Inspection.

Your's faithfully,

Perfected  
Office of the  
Fire Station T T L  
Secunderabad.